CE 0085

DVGW CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085BO0352
Product Identification No.
Produkt-Identnummer

Field of Application ***Anwendungsbereich***	EU Gas Appliances Regulation (EU/2016/426) *EU-Gasgeräteverordnung (EU/2016/426)*
Owner of Certificate ***Zertifikatinhaber***	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Distributor ***Vertreiber***	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Product Category ***Produktart***	gas fittings: Pressure regulator for LPG (4302)
Product Description ***Produktbezeichnung***	Pressure regulator for LPG with variable outlet pressure optional with excess flow device (EFV) and manometer
Model ***Modell***	912; 912 L; 915; 915 L
Countries of Destination ***Bestimmungsländer***	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports ***Prüfberichte***	supplement test: 705CL1900060 from 28.05.2019 (FGL)
Test Basis ***Prüfgrundlagen***	EU/2016/426 A III B (09.03.2016) DIN EN 16129 (01.08.2013)

70028-04-A-DE

Date of Expiry / File No. 03.04.2028 / 19-0121-GER
Ablaufdatum / AZ

19.06.2019 Rie A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

DAkkS
Deutsche Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Gas Category ***Gasart***	**Remarks** ***Bemerkungen***
LPG	

Type ***Typ***	**Technical Data** ***Technische Daten***	**Remarks** ***Bemerkungen***
912; 912 L; 915; 915 L	outlet pressure: 0,5...2,0, 0,5...4,0 (Propane); 0,5...1,5/4,0, 2,0...4,0 (LPG) bar inlet pressure range: 0,3...16,0 (LPG); 1,0...16,0 (Propan) bar nominal pressure rating: PN 16 nominal flow rate: 8,0...14,0 kg/h	

Type Variation ***Ausführungsvariante***	**Explanations** ***Erläuterungen***
912L; 915L	with excess flow device (EFV)

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

ambient temperature range: -20...+50 °C
connections: on the input side G1/G2/G4/G5/G6/G7/G8/G9/G10/G12/G14/G18/G25/G36, on the output side H1/H6/H7/H11/H50, each according to DIN EN 16129
In Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by Macedonia.